

IBN SINA HOSPITAL WATER TEST



The J&K Pollution Control Committee
Rajbagh, Srinagar Kashmir

Report No:-SPCB/ROK/W.Lab/AR/23-24/21
Date:-24/06/2023

Analysis Report

S.no	Parameter	ETP OF M/S IBN SINA HOSPITAL, OMPORA BUDGAM		
		District: Budgam		
Date of Sampling		RAW(Influent)	FINAL (Effluent)	Permissible limits
		17-06-2023		
1	Air Temperature		30.5	
2	Water Temperature			
3	pH	28.0	29.5	-
4	Dissolved Oxygen	7.31	7.52	5.5 to 9.0
5	Chemical Oxygen Demand	-	6.50	
6	Biochemical Oxygen Demand	377.2	166.70	250.0
7	Phosphate(PO ₄ -P)	136.5	24.0	30.0
8	Ammonical Nitrogen (NH ₃ -N)	3.642	1.373	5.0
9	Chloride	15.84	9.9	-
10	Total Suspended Solids	368.0	48.0	-
11	Total Dissolved Solids	-	32.0	100.0
		2000.0	370.00	-

Test analysis report reveals that all analyzed parameters are within prescribed permissible Norms.

sample Collected by

EST

Analysed by

[Signature]

[Signature]
I/C Water Lab